



Will Parnell <willparnell.ce@gmail.com>

The Lodge at Fossil Ridge 2020-008763 SP

Chu, Yanjun <Yanjun.Chu@austintexas.gov>

Wed, Mar 25, 2020 at 5:30 PM

To: Will Parnell <willparnell.ce@gmail.com>, "dprice@texasonsite.com" <dprice@texasonsite.com>

Cc: "Frazier, Katie" <Katie.Frazier@austintexas.gov>, "Kirk, Colleen" <Colleen.Kirk@austintexas.gov>, "Holmes, Reyna" <Reyna.Holmes@austintexas.gov>, "Pandurangi, Shwetha" <Shwetha.Pandurangi@austintexas.gov>, "Resendez, George" <George.Resendez@austintexas.gov>

March 25, 2020

Mr. David Price, P.E.

P.O. Box 26523

Austin TX 78755

Re: SP-2020-0025C OSSF Waiver Request[The Lodge at Fossil Ridge](#)[3306 Ferguson Lane, Austin](#)

OSSF Waiver Request Per Title 25, LDC, Chapter 25-12, Article6, 304.2

Dear Mr. Price:

The Austin Water has completed the review of your request regarding a waiver from the city code 25-12, Article6 section 304.2 requiring to connect to existing wastewater lines within 100 ft. After the review of the proposed plan, the request to install an OSSF has been approved if a septic system will be installed that meets all technical criteria.

This decision is made based on the cost of the project, the feasibility of the construction and the particular environmental concern.

Please note that this site is outside City of Austin OSSF jurisdiction and should contact Travis County for the OSSF permitting. Feel free to let us know if you have any further questions.

Best,

Yanjun(Julia) Chu, P.E., OS31817

Utility Development Services

City of Austin | Austin Water

512-972-0119 | Yanjun.Chu@austintexas.gov.

